

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** FRANKS QUICK STOP LLC  
1308 S HAYNES AVE  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-00624

**Last Inspected On:** 10/29/2014

**Operating Permit Renewal Date:** 2/13/2018

**Contact:** Franks NGO, (406) 853-1991

<b>Owners/Operators:</b> Franks Quick Stop LLC, Owner	(406)-234-6661	1308 SOUTH HAYNES AVE MILES CITY MT 59301
Frank Alan Ngo, Operator	(406)-234-6661	16 N 7TH ST MILES CITY MT 59301-3110
Frank Alan Ngo, UST Class A Operator		
Jenny Moran, UST Class B Operator		
Gerald Mace, UST Class B Global Operator		
Jason South, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	25	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1788</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/9/2011	TLS-350/Gilbarco EMC , Veeder Root		
9	25	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1789</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		10/8/2011	TLS-350/Gilbarco EMC , Veeder Root		
10	25	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1790</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		10/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		10/8/2011	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** M & H GAS MILES CITY  
1019 MAIN ST  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-01058

**Last Inspected On:** 4/8/2015

**Operating Permit Renewal Date:** 6/23/2018

**Contact:** Brandy Winkley, (406) 232-6838

**Owners/Operators:** Miller & Holmes Inc, Owner (715)-377-1730 2311 ONEIL RD  
HUDSON WI 54016-8168

Kevin Junker, UST Class A Operator  
Kevin Junker, UST Class B Operator  
Dave Lunder, UST Class B Operator  
Sandy Maine, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	21	10/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1613</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		11/11/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	21	10/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1614</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		11/11/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	21	10/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1615</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,500		11/11/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** M & H GAS MILES CITY  
1019 MAIN ST  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-01058

**Last Inspected On:** 4/8/2015

**Operating Permit Renewal Date:** 6/23/2018

**Contact:** Brandy Winkley, (406) 232-6838

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	21	10/1/1994	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
1616			None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Not Listed	
Diesel		4/8/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,500			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** MILES CITY BULK PLANT  
S 4TH ST & PACIFIC AVE PO BOX 1440  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-03211

**Last Inspected On:** 7/30/2015

**Operating Permit Renewal Date:** 8/3/2018

**Contact:** Dave Corbin, (406) 232-1350

**Owners/Operators:** Cenex Harvest States Sidney, Owner/Operator (406)-433-1401 PO BOX 1440  
MILES CITY MT 59301

David Corbin, UST Class A Operator  
Rick Harwood, UST Class A Operator  
David Corbin, UST Class B Operator  
Rick Harwood, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	38	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
<b>3586</b>			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Diesel		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		
2	38	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
<b>3587</b>			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Gasoline		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		
3	38	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
<b>3764</b>			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Diesel		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** MILES CITY BULK PLANT  
S 4TH ST & PACIFIC AVE PO BOX 1440  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-03211  
**Last Inspected On:** 7/30/2015  
**Operating Permit Renewal Date:** 8/3/2018

**Contact:** Dave Corbin, (406) 232-1350

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	38	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
<b>3588</b>			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Gasoline		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		
5	38	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
<b>3589</b>			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Diesel		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		
6	38	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
<b>3590</b>			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Diesel		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** THE SHORT STOP STORE  
16 N 7TH ST  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-04443

**Last Inspected On:** 3/18/2014

**Operating Permit Renewal Date:** 6/19/2017

**Contact:** Teresa Newby, (406) 234-6661

**Owners/Operators:** Frank Alan Ngo, Owner (406)-234-6661 16 N 7TH ST  
MILES CITY MT 59301-3110

Frank A Ngo, UST Class A Operator  
Frankie Meade, UST Class B Operator  
Frank A Ngo, UST Class B Operator  
Tony Russo, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	05	12/17/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>5284</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/1/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		12/23/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes
8	05	12/17/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>5285</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/1/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
5,000		12/21/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** GM PETROLEUM DISTRIBUTORS  
500 N 5TH ST  
MILES CITY, MT 59301 CUSTER  
**Contact:** Jay Brookie, (406) 252-4661

**Sys Fac ID:** 09-05859  
**Last Inspected On:** 6/11/2013  
**Operating Permit Renewal Date:** 11/15/2016

**Owners/Operators:** City Service Valcon LLC DBA GM Petroleum Distributors, (406)-252-4661 PO BOX 30335  
Owner/Operator BILLINGS MT 59101  
Bill Grunstead, UST Class A Operator  
Roger Schmechel, UST Class A Operator  
Laura Geffre, UST Class B Operator  
Roger Schmechel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	17	11/1/1998	Bare Steel	Steel	
<b>4009</b>	Yes		None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/11/2013	Deferred	MLLD Line Tightness Testing	
17,335		4/11/2013			
6	17	11/1/1998	Bare Steel	Steel	
<b>4010</b>	Yes		None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		6/11/2013	Deferred	MLLD Line Tightness Testing	
17,335		4/11/2013			
7	17	11/1/1998	Bare Steel	Steel	
<b>4011</b>	Yes		None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		6/11/2013	Deferred	MLLD Line Tightness Testing	
17,335		4/11/2013			
8	17	11/1/1998	Bare Steel	Steel	
<b>4012</b>	Yes		None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/11/2013	Deferred	MLLD Line Tightness Testing	
10,123		4/11/2013			

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** TOWN PUMP OF MILES CITY  
1210 S HAYNES AVE  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-07081

**Last Inspected On:** 3/7/2013

**Operating Permit Renewal Date:** 4/27/2016

**Contact:** Trent Biggers, (406) 497-6700

**Owners/Operators:** Western Catering Services Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000  
Trent Biggers, UST Class A Operator  
Daniel Sampson, UST Class A Operator  
Trent Biggers, UST Class B Global Operator  
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	5/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>2401</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/5/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	21	5/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>2402</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/5/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
3	21	5/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>2403</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/5/2013	Stat. Inventory Reconciliation	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root		



## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** TOWN PUMP OF MILES CITY  
1210 S HAYNES AVE  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-07081

**Last Inspected On:** 3/7/2013

**Operating Permit Renewal Date:** 4/27/2016

**Contact:** Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	21	1/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>2404</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	21	1/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>4890</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
6	21	1/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>4891</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring, Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
16	15	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4232</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** TOWN PUMP OF MILES CITY  
1210 S HAYNES AVE  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-07081

**Last Inspected On:** 3/7/2013

**Operating Permit Renewal Date:** 4/27/2016

**Contact:** Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
17	15	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4233</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring, Deferred	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
18	15	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4234</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring, Deferred	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
19	15	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4235</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring, Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
20	15	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4236</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** FRANK'S SHORT STOP II  
301 MAIN ST  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-07083

**Last Inspected On:** 3/17/2014

**Operating Permit Renewal Date:** 6/8/2017

**Contact:** Frank Ngo, (406) 853-1991

**Owners/Operators:** Frank's Short Stop, Owner/Operator (406)-853-1991 305 MAIN ST  
MILES CITY MT 59301

Frank Alan Ngo, UST Class A Operator  
Dyna Bennett, UST Class B Operator  
Gordon Dorothy, UST Class B Operator  
Jodien Twardoski, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	18	10/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>595</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/17/2014	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
11	18	10/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>596</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/17/2014	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
12	18	10/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>597</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/17/2014	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** VA MEDICAL CENTER MILES CITY  
210 S WINCHESTER AVE  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-07784

**Last Inspected On:** 7/9/2013

**Operating Permit Renewal Date:** 8/2/2016

**Contact:** Joe Dejong, (406) 232-8565

**Owners/Operators:** VA Medical Center, Owner (406)-232-3060 210 S WINCHESTER AVE  
MILES CITY MT 59301-4757

James L Arneson, UST Class A Operator

Joseph Dejong, UST Class A Operator

James L Arneson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	11/17/1992	Fiberglass Reinforced Plastic	Steel	High Level Alarm
<b>2194</b>			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
2,000					
4	34	4/22/1981	Fiberglass Reinforced Plastic	Steel	High Level Alarm
<b>2191</b>			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
5	34	4/22/1981	Fiberglass Reinforced Plastic	Steel	High Level Alarm
<b>2192</b>			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
7	23	4/20/1992	Fiberglass Reinforced Plastic	Steel	High Level Alarm
<b>2193</b>			None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** ZIP TRIP 59  
1321 S HAYNES AVE  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-08212

**Last Inspected On:** 3/18/2015

**Operating Permit Renewal Date:** 3/25/2018

**Contact:** (406) 232-4549

**Owners/Operators:** CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE  
SPOKANE VALLEY WA 99216  
Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE  
SPOKANE VALLEY WA 99216  
Ian Johnstone, UST Class A Operator  
Tom Savas, UST Class A Operator  
Chuck Crane, UST Class B Operator  
Darcy Ziegler, UST Class B Operator  
Roderick Crane, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	24	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
<b>547</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
9	24	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
<b>4347</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
10	24	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>552</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** ZIP TRIP 59  
1321 S HAYNES AVE  
MILES CITY, MT 59301 CUSTER  
**Contact:** (406) 232-4549

**Sys Fac ID:** 09-08212  
**Last Inspected On:** 3/18/2015  
**Operating Permit Renewal Date:** 3/25/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
11	24	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>4348</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
12	24	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>4349</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
13	24	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>551</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/21/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** QWEST MILES CITY CENTRAL OFFICE  
811 PLEASANT ST PO BOX 1178  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-08778

**Last Inspected On:** 10/21/2014

**Operating Permit Renewal Date:** 3/5/2018

**Contact:** kevin robison, (406) 232-4890

<b>Owners/Operators:</b> Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Thomas J Pitts, UST Class A Operator		
Kevin Robison, UST Class A Operator		
Thomas J Pitts, UST Class B Operator		
Kevin Robison, UST Class B Operator		
Thomas J Pitts, UST Class B Global Operator		
Kevin Robison, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1725			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
553		5/29/2013	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** HOLY ROSARY HOSPITAL WILSON ST  
2600 WILSON ST  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 09-13574

**Last Inspected On:** 1/13/2016

**Operating Permit Renewal Date:** 2/10/2019

**Contact:** Clyde Leischner, (406) 233-2600

**Owners/Operators:** Holy Rosary Hospital, Owner

(406)-233-2600

2600 WILSON ST STOP 1  
MILES CITY MT 59301-5016

Mike Ryan, UST Class A Operator

Shad Waldo, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	8/1/1994	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4284		12/8/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
8,000			ILS-350 , Veeder Root		



## Facility Summary in CUSTER County in the City of MILES CITY

**Location:** ENTERPRISE SYSTEMS SERVICE CENTER  
114 S HAYNES AVE  
MILES CITY, MT 59301 CUSTER

**Sys Fac ID:** 60-15140

**Last Inspected On:** 7/23/2013

**Operating Permit Renewal Date:** 9/18/2016

**Contact:** Michael Krings, (406) 444-1815

**Owners/Operators:** MT Dept of Administration ITSD, Owner (406)-444-2700 ITSD  
DEADHEAD  
HELENA MT 59620-0113

Michael Krings, UST Class A Operator  
John Salazar, UST Class A Operator  
Ed Sivils, UST Class A Operator  
John Salazar, UST Class B Operator  
Ed Sivils, UST Class B Operator  
Rennette Waldo, UST Class B Operator  
Randy Anderson, UST Class B Global Operator  
Zane Rudolph, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	06	7/21/2009	Unknown	Flexible Plastic	High Level Alarm
5215	Yes		Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		Yes